240 v
ac in

POWER SUPPLY UNIT

CIRCUIT BREAKER
71188B

24 v
DC out

ZONE CONTROLLER
72640B

ZA
ZB
A
A

GND
24V

ELECTRONIC MODULE
72573C

A
A
BB
BA

14
7c
7b
7a
6
5c
5b
5a
4
3
2c
2b
2a
1b
1a
ZB
ZA

GND
24V

ELECTRONIC MODULE
72571C

A
A
BB
BA

14
7c
7b
7a
6
5c
5b
5a
4
3
2c
2b
2a
1b
1a
ZB
ZA

GND
24V

ELECTRONIC MODULE
72570C

14
7c
7b
7a
6
5c
5b
5a
4
3
2c
2b
2a
1b
1a
ZB
ZA

GND
24V

DATABUS TERMINATOR
72642B



ZB
ZA
ZB
ZA

GND
24V

CANCEL UNIT
73642C



1
2
3
4

4
5
7



PULLCORD
70046A3

4
6
BB
BA

A
A
BB
BA
6
4



DISABLED REFUGE
DISPLAY POINT
STAINLESS STEEL
74910B3SS

ORANGE FROM RESET
BROWN FROM RESET
BLUE FROM CALL
GREY FROM CALL
WHITE FROM CALL

A
A
BB
BA
6
4



DISABLED REFUGE
CALL STATION
STAINLESS STEEL
74912A4SS

CABLE TYPE

SYSTEM CABLE 89734AJ

1 PAIR 1.5mm STRANDED — RED, BLUE

2 INDIVIDUALLY SCREENED PAIRS 0.5mm SOLID CORE
CABLE WITH OVERALL SCREEN — GREY, PINK, YELLOW, GREEN

ROOM / INPUT CABLE 981486A

6 CORES 0.2mm PVC/PVC STRANDED
RED
BLACK
YELLOW
BLUE
GREEN
WHITE

ISSUE	DESCRIPTION	APP	DATE
1.1	REVISION 1		26-7-07

SFS SYSTEMS LTD
8 FITZMAURICE COURT
STATION ROAD
WYMONDHAM
NORFOLK
NR18 0NN
Tel:- 01953 423232
Fax:- 01953 600272

TITLE

DISABLED REFUGE WITH DISABLED TOILET

STAINLESS STEEL SPEECH AND CALL UNITS

DRAWN	CHECKED	APPROVED	DATE
ST	TM	KR	17-3-04

DRAWING NUMBER
ACK-DR-WC-1005